

检验报告

Test Report

NO:2024-JAJC-BG0576

委托单位: 福建省万安消防器材有限公司

产品名称: 轻便消防水龙箱

产品型号: LQG16B



玖安检测认证有限公司

Jiu'an Testing and Certification Co.,Ltd

注意事項

REMARKS

1、报告无本公司“检验检测专用章”无效，报告涂改无效。

The report is invalid without the company's "Special seal for inspection and testing", and the report is invalid for alteration.

2、复制报告未重新加盖本公司“检验检测专用章”无效。

Copy the report is not re-stamped the company's "Special seal for inspection and testing" is invalid.

3、报告无编制、审核、批准人签字无效。

The report is invalid without the signature of the preparer, reviewer, or approver.

4、本报告未经本公司批准的复制（全文复制除外）或以其他任何形式的篡改均属无效。

Any copy of this report (except full-text copy) or any other form of tampering without the approval of the company shall be null and void.

5、对检验报告若有异议，请于收到报告之日起十五日内向本检验公司提出。

If you have any objection to the inspection report , please submit it to our inspection company within 15 days after receiving the report.

6、检验报告仅对受检样品负责，测试结果仅反映对该样品的评价。

The test report is only responsible for the sample under test, and the test results reflect only the evaluation of the sample.

7、委托单位对样品的代表性和资料的真实性负责，否则本检测公司不承担任何相关责任。

The entrusted entity shall be responsible for the representativeness of the samples and the authenticity of the data, otherwise the testing company shall not bear any relevant responsibility.





检验报告

NO:2024-JAJC-BG0576

第1页 共5页

产品名称	轻便消防水龙箱	商标	VAVAN
型号规格	LQG16B		
生产者	福建省万安消防器材有限公司		
生产企业	福建省万安消防器材有限公司		
检验类别	委托检验		
生产日期	2024年	到样日期	2024年03月12日
样品数量	1套	样品状态	完好
送样地点	玖安检测认证有限公司	检验时间	2024年03月13日
检验依据	Q/WAXF 001-2024《轻便消防水龙箱》		
检验项目	外观质量、外形尺寸和极限偏差；材料；箱体刚度；箱门；连接性能；喷射性能；水龙箱内配置轻便消防水龙的性能及尺寸；标志		
检验结论	经检验，所检项目符合 Q/WAXF 001-2024 标准要求，判定合格。		
备注			

批准: 陈瑞金

审核: 陈华荣

编制: 黄小亮

