



中国认可
国际互认
检测
TESTING
CNAS L20939

检验报告

Test Report

NO:2024-JAJC-BG1029

委托单位: 粤兴消防设备有限公司

产品名称: 沟槽式管接头

型号规格: XGQT1-88.9-2.5、XGQT1-114.3-2.5

XGQT1-165.1-2.5、XGQT1-219.1-2.5

检验类别: 委托检验



玖安检测认证有限公司

Jiu'an Testing and Certification Co.,Ltd

注意事項

REMARKS

1、报告无本公司“检验检测专用章”无效，报告涂改无效。

The report is invalid without the company's "Special seal for inspection and testing", and the report is invalid for alteration.

2、复制报告未重新加盖本公司“检验检测专用章”无效。

Copy the report is not re-stamped the company's "Special seal for inspection and testing" is invalid.

3、报告无编制、审核、批准人签字无效。

The report is invalid without the signature of the preparer, reviewer, or approver.

4、本报告未经本公司批准的复制（全文复制除外）或以其他任何形式的篡改均属无效。

Any copy of this report (except full-text copy) or any other form of tampering without the approval of the company shall be null and void.

5、对检验报告若有异议，请于收到报告之日起十五日内向本检验公司提出。

If you have any objection to the inspection report, please submit it to our inspection company within 15 days after receiving the report.

6、检验报告仅对受检样品负责，测试结果仅反映对该样品的评价。

The test report is only responsible for the sample under test, and the test results reflect only the evaluation of the sample.

7、委托单位对样品的代表性和资料的真实性负责，否则本检测公司不承担任何相关责任。

The entrusted entity shall be responsible for the representativeness of the samples and the authenticity of the data, otherwise the testing company shall not bear any relevant responsibility.

地址：福建省泉州市南安市溪美街道安山路1号 电话：0595-86068119

网址：www.jajczx.com 邮箱：jiuantesting@163.com 邮编：362300





检验报告

NO:2024-JAJC-BG1029

第1页 共3页

产品名称	沟槽式管接头	商标	
型号规格	XGQT1-88.9-2.5、XGQT1-114.3-2.5、XGQT1-165.1-2.5、XGQT1-219.1-2.5		
生产者	粤兴消防设备有限公司		
生产企业	粤兴消防设备有限公司		
检验类别	委托检验		
生产日期	2024年	到样日期	2024年06月25日
样品数量	各1只	样品状态	完好
送样地点	玖安检测认证有限公司	检验时间	2024年06月26日
检验依据	GB 5135.11-2006《自动喷水灭火系统 第11部分：沟槽式管接件》		
检验项目	外观；基本参数；密封性能；耐压强度		
检验结论	经检验，所检项目符合 GB 5135.11-2006 标准要求，判定合格 		
备注			

批准: 陈瑞金

审核: 孙达

编制: 黄小亮