

检 验 报 告

Test Report

NO:2024-JAJC-BG2494

委托单位：福建省南安市闽安消防设备厂

产品名称：智能室外消火栓

型号规格：SA100/65-1.6ZN

检验类别：委托检验



玖安检测认证有限公司

Jiu'an Testing and Certification Co.,Ltd



注 意 事 项

REMARKS

- 1、报告无本公司“检验检测专用章”无效，报告涂改无效。

The report is invalid without the company's "Special seal for inspection and testing", and the report is invalid for alteration.

- 2、复制报告未重新加盖本公司“检验检测专用章”无效。

Copy the report is not re-stamped the company's "Special seal for inspection and testing" is invalid.

- 3、报告无编制、审核、批准人签字无效。

The report is invalid without the signature of the preparer, reviewer, or approver.

- 4、本报告未经本公司批准的复制（全文复制除外）或以其他任何形式的篡改均属无效。

Any copy of this report (except full-text copy) or any other form of tampering without the approval of the company shall be null and void.

- 5、对检验报告若有异议，请于收到报告之日起十五日内向本检验公司提出。

If you have any objection to the inspection report, please submit it to our inspection company within 15 days after receiving the report.

- 6、检验报告仅对受检样品负责，测试结果仅反映对该样品的评价。

The test report is only responsible for the sample under test, and the test results reflect only the evaluation of the sample.

- 7、委托单位对样品的代表性和资料的真实性负责，否则本检测公司不承担任何相关责任。

The entrusted entity shall be responsible for the representativeness of the samples and the authenticity of the data, otherwise the testing company shall not bear any relevant responsibility.

地址：福建省泉州市南安市溪美街道安山路 1 号 电话：0595-86068119

网址：www.jajczz.com 邮箱：jiuantesting@163.com 邮编：362300



玖安检测认证有限公司

检 验 报 告

NO:2024-JAJC-BG2494

第 1 页 共 3 页

产品名称	智能室外消火栓	商标	
型号规格	SA100/65-1.6ZN		
生产者	福建省南安市闽安消防设备厂		
生产企业	福建省南安市闽安消防设备厂		
检验类别	委托检验		
生产日期	2024 年	到样日期	2024 年 12 月 27 日
样品数量	3 台	样品状态	完好
送样地点	玖安检测认证有限公司	检验时间	2024 年 12 月 28 日
检验依据	Q/MAXF 003-2023 《智能室外消火栓》		
检 验 项 目	水压监测功能；出水监测功能；积水监测功能；倾斜报警功能；定位、导航功能；信号强度监测功能；电池电压监测功能；用水计量功能		
检 验 结 论	经检验，所检项目符合 Q/MAXF 003-2023 标准要求，判定合格。  签发日期：2025 年 01 月 21 日		
备 注			

批准：陈瑞金

审核：戴少阳

编制：詹其轩