



221302110727



中国认可
国际互认
检测
TESTING
CNAS L20939

检验报告

Test Report

NO:2025-JAJC-BG0345



委托单位：福建省三辉消防器材有限公司

产品名称：水雾喷头

型号规格：ZSTW C28/120

检验类别：委托检验



玖安检测认证有限公司

Jiu'an Testing and Certification Co.,Ltd

注意事項

REMARKS

1、报告无本公司“检验检测专用章”无效，报告涂改无效。

The report is invalid without the company's "Special seal for inspection and testing", and the report is invalid for alteration.

2、复制报告未重新加盖本公司“检验检测专用章”无效。

Copy the report is not re-stamped the company's "Special seal for inspection and testing" is invalid.

3、报告无编制、审核、批准人签字无效。

The report is invalid without the signature of the preparer, reviewer, or approver.

4、本报告未经本公司批准的复制（全文复制除外）或以其他任何形式的篡改均属无效。

Any copy of this report (except full-text copy) or any other form of tampering without the approval of the company shall be null and void.

5、对检验报告若有异议，请于收到报告之日起十五日内向本检验公司提出。

If you have any objection to the inspection report, please submit it to our inspection company within 15 days after receiving the report.

6、检验报告仅对受检样品负责，测试结果仅反映对该样品的评价。

The test report is only responsible for the sample under test, and the test results reflect only the evaluation of the sample.

7、委托单位对样品的代表性和资料的真实性负责，否则本检测公司不承担任何相关责任。

The entrusted entity shall be responsible for the representativeness of the samples and the authenticity of the data, otherwise the testing company shall not bear any relevant responsibility.



玖安检测认证有限公司

检验报告

NO:2025-JAJC-BG0345

第1页 共3页

产品名称	水雾喷头	商标	三辉消防
型号规格	ZSTW C28/120		
生产者	福建省三辉消防器材有限公司		
生产企业	福建省三辉消防器材有限公司		
检验类别	委托检验		
生产日期	2025年	到样日期	2025年03月13日
样品数量	10只	样品状态	完好
送样地点	玖安检测认证有限公司	检验时间	2025年03月14日
检验依据	GB 5135.3-2003《自动喷水灭火系统 第3部分：水雾喷头》		
检验项目	流量系数；喷洒性能		
检验结论	经检验，所检项目符合 GB 5135.3-2003 标准要求，判定合格。		
备注			

批准: 卫东瑞金

审核: 戴少阳

编制: 廖其轩

